

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 11:45 am

PWS ID: UTAH04040 **Name:** SKYLINE MINE

Legal Contact: SKYLINE MINE **Rating:** Approved
TODD R POULSEN **Rating Date:** 04/09/1996

Address: HC35 BOX 380 **Activity Status:** Active
HELPER, UT 84526

Phone Number: 435-448-2616

City Served (Area):

County: CARBON COUNTY

System Type: Non Transient **Last Inv Update:** 08/12/2010 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 07/31/2009 **Total Dsgn Cap:**
Population: 150 **Surveyor:** STEVEN J ONYSKO **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	POULSEN, TODD R		435-448-2616	435-462-3335	tpoulsen@archcoal.com

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Metered	0	1
			1 Total Svc Connections

Storage

Total Storage: 51,500 GAL **Number of Units:** 2 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matl	Overflow Elev	Activity Status	Press'd
ST002	1500 GALLON WTP CLEARWELL	UK	1,500 GAL			A	
ST001	50K GALLON WATER TANK ST001	Ground	50,000 GAL	Steel		A	

Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	WTP & CL2		I	

Pumping Stations

Facility No	Facility Name	Activity Status	Capacity	Avail	Emerg Power	Operating Category	Total Dynamic Head
PF001	FILTERS-TO-15K GALLON CLEAR	A					
PF002	15K GAL. CLEARWELL-TO-FILTER	A					
PF003	15K GAL. CLEARWELL-TO-50K GA	A					

Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	WELL #1	Active	WL	6	90 GPM	52 GPM	Yes	GW	Permanent	1/1 to 12/31	

**Reports measured flow for wells, approved design capacity for all other sources.*